

Pressure Sewerage Code of Australia

Requirement	Clause																				
<p>Materials approved for use in PWC systems are listed in the PWC document 'Water and Sewerage Supply Infrastructure Products Manual' and any additional requirements specified in the 'Water Supply and Sewerage Construction Master Specification'.</p> <p>Application for use of alternative materials may be submitted to PWC for approval however processing of such applications may take some time and may be rejected at the discretion of PWC.</p> <p>In Table 10.1, delete reference to WSA PS-209S, WSA PS-211S, WSA PS-213S, WSA PS-260, WSA PS-264, WSA PS-274, WSA PS-290 and WSA PS-318.</p> <p>In Table 10.1, delete 'WSA PS-207S' and insert 'WSA PS-207', delete 'WSA PS-208S' and insert 'WSA PS-208' and delete 'WSA PS-216S' and insert 'WSA PS-216'.</p>	10.4.2																				
<p>Before the first paragraph, add:</p> <p>"For operational reasons, PWC has limited the sizes of PN16 PE100 pipe within its pressure sewer system to DN40, 50, 63, 90, 110, 160, 225, 280 and 315."</p> <p>Delete the fourth paragraph (<i>As at October 2005...</i>).</p> <p>Delete Table 10.2 and insert the following:</p> <p style="text-align: center;">TABLE 10.2 INTERNAL DIAMETERS OF PE PIPES</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Pipe Size DN</th> <th>Nominal Internal Diameter (mm) PE100 SDR11 PN16</th> </tr> </thead> <tbody> <tr><td>40</td><td>32.3</td></tr> <tr><td>50</td><td>40.5</td></tr> <tr><td>63</td><td>51.0</td></tr> <tr><td>90</td><td>73.1</td></tr> <tr><td>110</td><td>89.4</td></tr> <tr><td>160</td><td>130.0</td></tr> <tr><td>225</td><td>182.9</td></tr> <tr><td>280</td><td>227.8</td></tr> <tr><td>315</td><td>256.3</td></tr> </tbody> </table>	Pipe Size DN	Nominal Internal Diameter (mm) PE100 SDR11 PN16	40	32.3	50	40.5	63	51.0	90	73.1	110	89.4	160	130.0	225	182.9	280	227.8	315	256.3	10.7.2
Pipe Size DN	Nominal Internal Diameter (mm) PE100 SDR11 PN16																				
40	32.3																				
50	40.5																				
63	51.0																				
90	73.1																				
110	89.4																				
160	130.0																				
225	182.9																				
280	227.8																				
315	256.3																				
<p>Delete 'cream striped black' and insert 'solid cream or sheathed cream'.</p> <p>Delete 'PE80B'.</p> <p>Delete 'WSA PS-207S' and insert 'WSA PS-207'.</p> <p>Delete 'WSA PS-208S' and insert 'WSA PS-208'.</p>	10.7.3																				
<p>PVC-U and PVC-M pipe and fittings shall comply with the requirements of the PWC Water and Sewer Approved Products Manual.</p>	10.7.5																				